

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD—
LOS ANGELES REGION

107 SOUTH BROADWAY, SUITE 4027
LOS ANGELES, CALIFORNIA 90012-4596
(213) 620-4460

SFUND RECORDS CTR
88130473



SFUND RECORDS CTR
2166-01052

May 15, 1985

Mr. Christopher M. Andrews
Manager-Engineering Quality
Control & Facilities
Airwork Corporation
Millville, N.J. 08332

UNDERGROUND TANK PIPELINE LEAK-PACIFIC AIRMOTIVE CORP.
(File No. 83-8) (ID #915050061)

Reference is made to your letter dated April 13, 1985, transmitting Kennedy/Jenks Engs. Phase II-Detailed Site Assessment report and the proposed Remedial Action Plan for your facility located at 2940 N. Hollywood Way, Burbank, CA.

We have reviewed Phase I and Phase II Site Assessment results which identified two (2) localized contamination plumes (jet fuel) extending to a vertical depth of between 25 and 30 feet below grade, in soils adjacent to Test Cell #4.

We have also reviewed your Site Cleanup Plan and have no objections to you implementing it, provided that all work is completed as specified in your proposal, and that a soil sampling and analysis program is conducted at the depths of each excavation (Area 1 and Area 2), as discussed in a telephone conversation between Mr. Noel Lerner of Kennedy/Jenks Engs. and Mr. David Bacharowski of this Board's staff on May 7, 1985.

Please notify us prior to the date you plan to begin work onsite, so we can schedule an inspector to be present.

If you have any questions concerning this matter, please contact me at (213) 620-5662 or Mr. David Bacharowski at (213) 620-5647.

JOSHUA M. WORKMAN
Senior Water Resource
Control Engineer

DAB:pag

cc: Mr. Noel Lerner, Project Engineer,
Kennedy/Jenks Engs.
Mr. B. Wettstein, Pacific Airmotive Corp.